



Sanitary Sewer Overflow Annual Report Division of Surface Water

Date: 01/23/2024		
Facility Name: Orrville WWTP		
Ohio NPDES Permit Number: 3PD00017*MD		
Period Covered by Report: 01/01/2023 - 12/31/2023		
Contact Person: Steven Carathers		Title: Superintendent
Mailing Address: 1530 North Main Street		
City: Orrville	State: OH	Zip Code: 44667
Country: USA		
Sanitary Sewer Overflows Spreadsheet(attachment) : 2023 SSO.xlsm		
Water In Basement Occurrences Spreadsheet(attachment) : WIB 2023.xlsm		
<p>Narrative analysis of WIB patterns by location, frequency and cause: Zone 0 had 1 WIB due to root issues. The area is on a three year treatment rotation, re-treating in second year, adjusting schedule to every other year.</p> <p>Zone 5 had 1 WIB due to grease and root issues. Visited area grease traps, had issues addressed.</p> <p>Zone 6 had 3 WIB due to Blockage in customer lateral.</p> <p>Zone 7 had 3 WIB due to Blockage in customer lateral.</p> <p>ZONE 9 had 1 WIB due to Blockage in customer lateral.</p>		
ADDITIONAL INFORMATION		
<i>Please add any additional comments or attachments below.</i>		
Certification		
<p><i>I certify under penalty of law that I have personally examined and am familiar with the information in this report and all attachments. Based on my inquiry of those persons immediately responsible for obtaining the information contained in the report, I believe that the information is true, accurate, and complete.</i></p>		
Name: Steven Carathers		Title: Superintendent
Signature(Electronically submitted by): Steven Carathers (User ID: scarathers)		Submission Date: 01/23/2024

